

Drinking Water Quality Annual Report Data 01/07/2022 to 30/06/2023

Table 11

Health related variables

Goldfields and Agricultural Region	E. coli			Thermophilic Naegleria			Fluoride			Hydrocarbons		Metals				
	Samples Taken	Samples >0 cfu/100mL	Max cfu/100mL	Requirement Met	Samples Taken	Samples with Thermophilic Naegleria	Requirement Met	Samples Taken	Concentration (mg/L)			Guideline Met	Samples Taken	Guideline Met	Samples Taken	Guideline Met
									Min	Max	Mean					
Ardath	12	0	0	✓	12	0	✓	2	0.85	0.95	0.90	(2)	0	(1)	2	✓
Avon Hills	60	0	0	✓	60	0	✓	2	0.75	0.80	0.78	(2)	0	(1)	2	✓
Ballidu	12	0	0	✓	12	0	✓	2	0.80	0.80	0.80	(2)	0	(1)	2	✓
Beacon	12	0	0	✓	12	0	✓	2	0.70	0.85	0.78	(2)	0	(1)	2	✓
Bencubbin	12	0	0	✓	12	0	✓	2	0.70	0.85	0.78	(2)	1	✓	2	✓
Beverley	52	0	0	✓	26	0	✓	2	0.75	0.90	0.83	(2)	0	(1)	2	✓
Bindi Bindi	12	0	0	✓	12	0	✓	2	0.80	0.90	0.85	(2)	0	(1)	2	✓
Broad Arrow	12	0	0	✓	12	0	✓	2	0.75	0.90	0.83	(2)	0	(1)	2	✓
Bruce Rock	52	0	0	✓	12	0	✓	2	0.75	0.95	0.85	(2)	1	✓	2	✓
Bullfinch	12	0	0	✓	12	0	✓	2	0.80	0.85	0.83	(2)	1	✓	2	✓
Buntine	12	0	0	✓	12	0	✓	2	0.75	0.85	0.80	(2)	0	(1)	2	✓
Cadoux	12	0	0	✓	12	0	✓	2	0.80	0.85	0.83	(2)	0	(1)	2	✓
Coolgardie	52	0	0	✓	26	0	✓	2	0.80	0.90	0.85	(2)	0	(1)	2	✓
Corrigin	52	0	0	✓	26	0	✓	2	0.80	0.85	0.83	(2)	0	(1)	2	✓
Cunderdin	52	0	0	✓	12	0	✓	2	0.70	0.90	0.80	(2)	0	(1)	2	✓
Dalwallinu	52	0	0	✓	12	0	✓	2	0.75	0.85	0.80	(2)	0	(1)	2	✓
Dowerin	12	0	0	✓	12	0	✓	2	0.80	0.85	0.83	(2)	0	(1)	2	✓
Goomalling	52	0	0	✓	12	0	✓	2	0.75	0.85	0.80	(2)	0	(1)	2	✓
Greater Bodallin	12	0	0	✓	12	0	✓	2	0.80	0.85	0.83	(2)	0	(1)	2	✓
Greater Burracoppin	36	0	0	✓	36	0	✓	2	0.90	1.00	0.95	(2)	0	(1)	2	✓
Greater Doodlakine	36	0	0	✓	36	0	✓	2	0.85	0.85	0.85	(2)	0	(1)	2	✓
Greater Meckering	39	0	0	✓	39	0	✓	2	0.75	0.85	0.80	(2)	0	(1)	2	✓
Greenhills	12	0	0	✓	12	0	✓	1	0.85	0.85	0.85	(2)	0	(1)	2	✓
Jennacubbine	12	0	0	✓	12	0	✓	2	0.85	0.90	0.88	(2)	0	(1)	2	✓
Kalannie	12	0	0	✓	12	0	✓	2	0.80	0.90	0.85	(2)	0	(1)	2	✓
Kalgoorlie	156	0	0	✓	130	0	✓	54	0.75	0.95	0.85	(2)	0	(1)	2	✓
Kambalda	52	0	0	✓	52	0	✓	2	0.85	0.85	0.85	(2)	0	(1)	2	✓
Kellerberrin	52	0	0	✓	26	0	✓	2	0.80	0.85	0.83	(2)	0	(1)	2	✓
Kooyanobbing	12	0	0	✓	12	0	✓	2	0.80	0.90	0.85	(2)	0	(1)	2	✓
Koorda	12	0	0	✓	12	0	✓	2	0.80	0.85	0.83	(2)	0	(1)	2	✓
Kununoppin	12	0	0	✓	12	0	✓	2	0.80	0.85	0.83	(2)	0	(1)	2	✓
Laverton	12	0	0	✓	12	0	✓	4	0.60	1.00	0.81	(3)	0	(1)	2	✓
Leonora	52	0	0	✓	25	0	✓	2	0.45	0.50	0.48	(3)	0	(1)	2	✓
Marvel Loch	11	0	0	✓	11	0	✓	2	0.75	0.80	0.78	(2)	0	(1)	2	✓
Menzies	12	0	0	✓	12	0	✓	2	0.75	0.95	0.85	(2)	0	(1)	2	✓
Merredin	52	0	0	✓	52	0	✓	49	0.75	0.95	0.84	(2)	0	(1)	2	✓
Miling	12	0	0	✓	12	0	✓	2	0.80	0.85	0.83	(2)	0	(1)	2	✓
Mukinbudin	11	0	0	✓	11	0	✓	2	0.70	0.85	0.78	(2)	0	(1)	2	✓
Muntadgin	12	0	0	✓	12	0	✓	2	0.80	0.90	0.85	(2)	0	(1)	2	✓
Narembeen	12	0	0	✓	12	0	✓	2	0.80	0.80	0.80	(2)	0	(1)	2	✓
Norseman	52	0	0	✓	26	0	✓	2	0.80	0.90	0.85	(2)	0	(1)	2	✓
Northam	78	0	0	✓	65	0	✓	52	0.70	0.90	0.84	(2)	0	(1)	2	✓
Nungarin	12	0	0	✓	12	0	✓	2	0.80	0.85	0.83	(2)	0	(1)	2	✓
Ora Banda	12	0	0	✓	12	0	✓	2	0.80	0.85	0.83	(2)	0	(1)	2	✓
Pithara	12	0	0	✓	12	0	✓	2	0.75	0.90	0.83	(2)	0	(1)	2	✓
Quairading	52	0	0	✓	25	0	✓	2	0.85	0.85	0.85	(2)	0	(1)	2	✓
Seabrook	12	0	0	✓	12	0	✓	2	0.75	0.85	0.80	(2)	0	(1)	2	✓
Shackleton	12	0	0	✓	12	0	✓	2	0.80	0.90	0.85	(2)	0	(1)	2	✓
Southern Cross	52	0	0	✓	39	0	✓	2	0.80	0.85	0.83	(2)	0	(1)	2	✓
Spencers Brook	12	0	0	✓	12	0	✓	2	0.80	0.90	0.85	(2)	0	(1)	2	✓
Tammin	24	0	0	✓	24	0	✓	2	0.75	0.85	0.80	(2)	0	(1)	2	✓
Toodyay	52	0	0	✓	26	0	✓	2	0.80	0.80	0.80	(2)	0	(1)	2	✓
Trayning	12	0	0	✓	12	0	✓	2	0.80	0.85	0.83	(2)	0	(1)	2	✓
Warralakin	12	0	0	✓	12	0	✓	2	0.75	0.80	0.78	(2)	0	(1)	2	✓
Westonia	12	0	0	✓	12	0	✓	2	0.85	0.90	0.88	(2)	0	(1)	2	✓
Wiluna	13	0	0	✓	13	0	✓	2	0.25	0.25	0.25	✓	0	(1)	2	✓
Wongan Hills	52	0	0	✓	39	0	✓	2	0.75	0.80	0.78	(2)	0	(1)	2	✓
Wubin	12	0	0	✓	12	0	✓	2	0.80	0.85	0.83	(2)	0	(1)	2	✓
Wyalkatchem	12	0	0	✓	12	0	✓	2	0.80	0.85	0.83	(2)	0	(1)	2	✓
York	78	0	0	✓	78	0	✓	52	0.70	0.95	0.83	(2)	0	(1)	2	✓

(1) No samples required in this 12 month period (2) Receives water from a fluoridated source within the dosing range set by the Fluoridation of Water Supplies Advisory Committee (3) Naturally occurring fluoride below the ADWG guideline.

Drinking Water Quality Annual Report Data 01/07/2022 to 30/06/2023

Goldfields and Agricultural Region		Health related variables														
Locality	Samples Taken	Nitrate				Pesticides		Radiological		Trihalomethanes				Other Health Related		
		Concentration (mg/L)			*Guideline Met	Samples Taken	Guideline Met	Samples Taken	Guideline Met	Concentration (mg/L)			Guideline Met	Samples Taken	Requirement Met	
		Min	Max	Mean						Min	Max	Mean				
Ardath	2	0.9	4.0	2.2	✓	1	✓	0	(1)	2	0.025	0.026	0.026	✓	0	(1)
Avon Hills	2	0.4	0.9	0.9	✓	1	✓	0	(1)	2	0.040	0.049	0.045	✓	0	(1)
Ballidu	2	0.9	1.3	0.9	✓	1	✓	2	✓	2	0.033	0.046	0.040	✓	0	(1)
Beacon	2	1.3	1.8	1.8	✓	1	✓	0	(1)	2	0.024	0.030	0.027	✓	0	(1)
Bencubbin	2	1.3	4.4	2.6	✓	1	✓	0	(1)	2	0.024	0.160	0.092	✓	0	(1)
Beverley	2	1.3	1.8	1.8	✓	1	✓	2	✓	2	0.025	0.033	0.029	✓	0	(1)
Bindi Bindi	2	2.2	2.6	2.2	✓	1	✓	0	(1)	2	0.026	0.032	0.029	✓	0	(1)
Broad Arrow	2	1.3	2.6	1.8	✓	1	✓	0	(1)	2	0.092	0.110	0.101	✓	1	✓
Bruce Rock	2	0.9	1.3	0.9	✓	1	✓	0	(1)	2	0.020	0.036	0.028	✓	0	(1)
Bullfinch	2	3.1	5.7	4.4	✓	1	✓	2	✓	2	0.054	0.074	0.064	✓	2	✓
Buntine	2	1.8	3.1	2.6	✓	1	✓	0	(1)	2	0.091	0.180	0.136	✓	0	(1)
Cadoux	2	0.4	1.8	0.9	✓	1	✓	0	(1)	2	0.027	0.044	0.036	✓	0	(1)
Coolgardie	2	1.3	1.3	1.3	✓	1	✓	0	(1)	2	0.053	0.067	0.060	✓	0	(1)
Corrigin	2	0.9	2.2	1.8	✓	1	✓	0	(1)	2	0.015	0.016	0.016	✓	0	(1)
Cunderdin	2	0.4	0.9	0.9	✓	1	✓	0	(1)	2	0.035	0.043	0.039	✓	0	(1)
Dalwallinu	2	0.9	1.3	0.9	✓	1	✓	0	(1)	2	0.018	0.030	0.024	✓	0	(1)
Dowerin	2	1.3	1.3	1.3	✓	1	✓	2	✓	2	0.029	0.045	0.037	✓	0	(1)
Goomalling	2	0.9	1.3	0.9	✓	1	✓	0	(1)	2	0.029	0.044	0.037	✓	0	(1)
Greater Bodallin	2	0.9	0.9	0.9	✓	1	✓	0	(1)	2	0.023	0.028	0.026	✓	0	(1)
Greater Burracoppin	2	0.9	0.9	0.9	✓	1	✓	0	(1)	2	0.021	0.037	0.029	✓	0	(1)
Greater Doodlakine	2	0.9	0.9	0.9	✓	1	✓	0	(1)	2	0.039	0.045	0.042	✓	0	(1)
Greater Meckering	2	0.4	0.9	0.9	✓	1	✓	0	(1)	2	0.039	0.040	0.040	✓	0	(1)
Greenhills	2	0.9	2.2	1.8	✓	1	✓	0	(1)	2	0.027	0.030	0.029	✓	0	(1)
Jennacubbine	2	2.2	2.6	2.6	✓	1	✓	2	✓	2	0.027	0.031	0.029	✓	0	(1)
Kalannie	2	2.6	3.5	3.1	✓	1	✓	0	(1)	2	0.030	0.074	0.052	✓	0	(1)
Kalgoorlie	2	1.3	1.3	1.3	✓	1	✓	0	(1)	2	0.110	0.160	0.135	✓	0	(1)
Kambalda	2	1.3	1.3	1.3	✓	1	✓	2	✓	4	0.077	0.160	0.117	✓	0	(1)
Kellerberrin	2	0.4	0.9	0.9	✓	1	✓	2	(1)	2	0.041	0.070	0.056	✓	0	(1)
Koolyanobbing	2	0.9	1.3	0.9	✓	1	✓	1	✓	2	0.006	0.020	0.013	✓	0	(1)
Koorda	2	0.9	1.3	0.9	✓	1	✓	0	(1)	2	0.023	0.035	0.029	✓	0	(1)
Kununoppin	2	2.2	2.6	2.2	✓	1	✓	0	(1)	2	0.013	0.034	0.024	✓	0	(1)
Laverton*	10	35.2	38.7	37.8	✓	1	✓	2	✓	2	0.025	0.057	0.041	✓	0	(1)
Leonora*	10	27.7	33.9	29.9	✓	1	✓	2	✓	2	<0.001	0.002	<0.001	✓	0	(1)
Marvel Loch	2	0.9	3.5	2.2	✓	1	✓	0	(1)	2	0.024	0.052	0.038	✓	0	(1)
Menzies*	5	1.3	7.9	3.5	✓	1	✓	0	(1)	2	0.081	0.090	0.086	✓	0	(1)
Merredin	2	0.9	1.3	0.9	✓	1	✓	2	✓	2	0.020	0.025	0.023	✓	0	(1)
Miling	2	1.3	2.2	1.8	✓	1	✓	2	✓	2	0.023	0.028	0.026	✓	0	(1)
Mukinbudin	2	0.9	1.3	0.9	✓	1	✓	0	(1)	2	0.027	0.041	0.034	✓	0	(1)
Muntadgin	2	0.9	4.8	3.1	✓	1	✓	1	✓	2	0.025	0.065	0.045	✓	0	(1)
Narembeen	2	0.9	1.3	1.3	✓	1	✓	0	(1)	2	0.027	0.030	0.029	✓	0	(1)
Norseman	2	1.8	2.2	1.8	✓	1	✓	0	(1)	2	0.026	0.054	0.040	✓	0	(1)
Northam	2	1.3	1.8	1.3	✓	1	✓	0	(1)	2	0.029	0.040	0.035	✓	0	(1)
Nungarin	2	0.9	1.3	0.9	✓	1	✓	0	(1)	2	0.011	0.049	0.030	✓	0	(1)
Ora Banda	2	1.3	1.8	1.3	✓	1	✓	0	(1)	2	0.022	0.085	0.054	✓	0	(1)
Pithara	2	0.9	1.3	0.9	✓	1	✓	0	(1)	2	0.031	0.043	0.037	✓	0	(1)
Quairading	2	0.9	0.9	0.9	✓	1	✓	2	✓	2	0.032	0.056	0.044	✓	0	(1)
Seabrook	2	0.9	0.9	0.9	✓	1	✓	1	✓	2	0.040	0.047	0.044	✓	0	(1)
Shackleton	2	0.9	4.0	2.6	✓	1	✓	0	(1)	2	0.039	0.042	0.041	✓	0	(1)
Southern Cross	2	0.9	0.9	0.9	✓	1	✓	0	(1)	2	0.017	0.025	0.021	✓	0	(1)
Spencers Brook	2	0.9	0.9	0.9	✓	1	✓	2	✓	2	0.037	0.049	0.043	✓	0	(1)
Tammin	2	0.4	0.9	0.9	✓	1	✓	0	(1)	2	0.035	0.043	0.039	✓	0	(1)
Toodyay	2	0.9	0.9	0.9	✓	1	✓	0	(1)	2	0.038	0.053	0.046	✓	0	(1)
Trayning	2	2.2	2.6	2.2	✓	1	✓	0	(1)	2	0.024	0.033	0.029	✓	0	(1)
Warralakin	2	0.9	1.3	0.9	✓	1	✓	0	(1)	2	0.022	0.028	0.025	✓	0	(1)
Westonia	2	0.9	1.8	1.3	✓	1	✓	0	(1)	2	0.025	0.036	0.031	✓	0	(1)
Wiluna*	2	32.1	40.9	36.5	✓	1	✓	1	✓	2	0.002	0.004	0.003	✓	0	(1)
Wongan Hills	2	1.3	1.3	1.3	✓	1	✓	0	(1)	2	0.025	0.035	0.030	✓	0	(1)
Wubin	2	1.3	2.2	1.8	✓	1	✓	0	(1)	2	0.007	0.030	0.018	✓	0	(1)
Wyalkatchem	2	0.9	1.3	0.9	✓	1	✓	0	(1)	2	0.032	0.047	0.040	✓	0	(1)
York	2	0.9	0.9	0.9	✓	1	✓	0	(1)	2	0.033	0.045	0.039	✓	0	(1)

(1) No samples required in this 12 month period.

\*Wiluna, Laverton, Leonora and Menzies have been granted an exemption from compliance with the infant health nitrate guideline by the Department of Health, however, following treatment or operational intervention these towns have achieved compliance with the infant health limit. Carers of infants younger than 3 months should seek advice from the Community Health Nurse regarding the use of alternative water sources for the preparation of bottle feeds. The Water Corporation provides bottled water free of charge for this purpose. Note: The water supplied has always met the guideline for adults and children over the age of 3 months - for a full list of towns with nitrate exemptions and how we are improving water quality in these towns - please refer to 'Understanding water quality test results - Nitrate' section of the annual report.